




Single Duct Constant Air Volume (CAV) Terminal Unit
Cooling Only
Pressure Independent
Model: BAC-8001

If controllers are to be networked together, turn **ON** EOL dip switches on the controllers at both physical ends of the network. Connect shield to earth ground at only one point.




NOTES:

1. Controller settings must be initially set using an STE-8XXX.
2. See SimplyVAV.com for accessories and additional details.

SEQUENCE OF OPERATION:

1. Airflow setpoint is maintained.



© 2014 KMC CONTROLS, INC.



KMC CONTROLS, INC.
19476 INDUSTRIAL DR.
NEW PARIS, IN 46553
PHONE: 574.831.5250
FAX: 574.831.5252
SimplyVAV.com

DRAWING TITLE: SINGLE DUCT TERMINAL UNIT - CAV

CREATION DATE: 3/7/2014

FILENAME: SS14017A_SimplyVAV_SD_CAV

REVISION DATE: 3/7/2014

REVISION: INITIAL RELEASE